

Product Change Notification

Date: May 2020



Affected product:
 NX232A-240A, NX232A-110A, NX232A-240A6, NX232A-110A6

Effective Date of Change:
1st July 2020

Device Identification:
 NX232A-240A and NX232A-110A with starting from serial number **1860152** onwards

Description of change:

Comparison Table between Old NX232A series and New NX232A series

Features	Old NX232A relay models	New NX232A relay models
Test Button Colour Change		
Auxiliary Supply Frequency	Frequency 50Hz or 60Hz need to be selected during purchase of the product	Frequency selectable during setting time by the user for 50Hz or 60Hz system
Display Function	Display will turn off automatically after a while	Display can be set to turn off or permanently turn on, with display scroll function
Fault Record	One non-volatile fault record	Three non-volatile fault record with elapse time
Reset Button Function	Reset button only used for resetting	Reset button can be used for reset and press 2 seconds for default display
Earth Fault Default Setting	2.00A	0.50A
Low-set time multiplier setting range, ktlo>	0.05 ~ 1.00	0.01 ~ 1.00
Low set definite time delay setting range, tlo>	0.05 ~ 99s	0 ~ 100s
High set definite time delay setting range, tlo>>	0.05 ~ 2.5s	0 ~ 100s

The new catalogue with the changes can be found at:
<http://www.itmikro.com/app/webroot/UploadedContent/files/NX232A.pdf>

Last time buy opportunity will be on a first come first basis while stock last.

Inquiry: Please contact Mikro at Tel: 603-5525 3863, Fax: 603-5525 3873,
 E-mail: mikro@itmikro.com with any questions or concerns.